

## 400 SERIES Commercial Strip Windows

### TEST REPORT SUMMARY

In compliance to AAMA/  
101/I.S.2/ CSA A440

<b>TEST SIZE</b>	2032mm x 2032mm
	80" x 80"

TYPE	TEST	REQUIREMENTS		RESULTS	GRADE	
		TEST STANDARD	TEST CRITERIA		AAMA	CSA
F I X E D	Air Tightness	ASTM E 283	299 Pa (6.24 psf)	0.010 cfm/ft <sup>2</sup>	PASS	FIXED
	Water Tightness	ASTM E 547	500 Pa (10.44 psf)	No Leakage	DP 65	B5
	Wind Load Resistance	ASTM E 330	4300 Pa (89.6 psf)	No Deformation	DP 55	C4

Series 400 Fixed window is rated F-HC 55, Design Pressure 55 @ test pressure 290 kph (180 mph).

**Note: The reader is cautioned that test results should be used for comparison purposes only. Results are size and installation dependent. In-Service performance can be significantly different from those shown.**

© Copyright Inline Fiberglass Ltd. of Toronto, Canada 2010.